

Client Code: CL-0002

Sample Code: WS0705-08

Water Quality Report

Customer:	Little Wonders Primary School	
Sampling Location:	Little Wonders Primary School	
Date, time of sampling:	04-May-2026	11:55:00 AM
Date, time of arrival at lab:	04-May-2026	1:10:00 PM
Date of completion:	06-05-2026	
Date Report Issued:	07-May-2026	
Volume in liters	0.5	Liters
Description:	A clear solvent sample	

Results

(US EAS 2012: 2017 STANDARD FOR TREATED PORTABLE WATER)

Parameter	Code	Test Method	US EAS 12: 2017	Result	Units
Total coliform, CFU/100ml	B01	ISO 9308	<1	<1	CFU per 100 mL
E. Coli, CFU/100 mL	B02	ISO 9308	<1	<1	CFU per 100 mL
Total Plate Count at 37°C ml, Max	B03	ISO 6222	<50	<1 CFU/ml	mL
Sodium, as Na+	C11	ISO 9964-1	<200	038	mg/L

Laboratory remarks: The water sample, **WS0705-08**, at "Little Wonders Primary School - Kampala," was found to conform to the requirements of the **US EAS 12:2017 STANDARD FOR TREATED POTABLE WATER** for the parameters analyzed.

07/5/2026

Date

Sulman Muhanguzi

Laboratory Manager

Signature



[Handwritten Signature]